



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6018498
Permit #: 00611-2023UPG
Request Rec'd: 06/08/2023
Approval Date: 06/08/2023 DS
Permit Expires: 12/08/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	FACILITY - name and address where tanks are located: Pilot Travel Center #249 820 Edwardsville Road Troy, IL 62294 Madison County Contact: Pat Heinkebein 618/667-0946
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
12	Gasoline - Premium	6,000	Currently in use	Federal

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	New
Piping	Other Steel Riser	New

Summary of Work Files

See summary of work files attached to the permit application.

Summary of Work

2. Saw cut and demo around the premium interstice manhole, there is an adjacent 18" manhole that will be in the demo, load and dispose of the concrete.
3. Dig to the tank top and remove the 4" riser pipe.
4. Remove the existing sensor and install a new sensor.
5. Install a new 4" PVC riser & cap.
6. Make wire connections and confirm operation.
7. Backfill, furnish and set two (2) 18" manholes, pin to the existing concrete and re-pour.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4618 Email: HEATHER_HINDS@NEUMAYEREQUIPMENT.COM Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

Daniel G. Starks

Daniel Starks