



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3034438
Permit #: 00618-2023UPG
Request Rec'd: 06/12/2023
Approval Date: 06/12/2023 DS
Permit Expires: 12/12/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's General Store # 1900 1850 South Main Morton, IL 61550 Tazewell County Contact: Stephanie Underwood 309/263-7049
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/L	Replacing - Piping - Fiberglass Double Wall Ameron

Summary of Work

Work was started under an emergency repair permit #00584-2023UPG. Due to not being able to locate and repair the leak within the allotted time for the emergency permit, a new permit was requested by the OSFM. The existing double wall piping run from the existing UST to dispenser island 5/6 will be replaced. A new formless concrete island will be constructed. The existing single wall containment system for both the UST and the UDC will remain. All other existing double wall piping will remain.

Special Contingencies

Replaced piping exceeds 20 feet or 50% of the total pipe run.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2024

Sincerely,

Daniel Starks