



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1001152
Permit #: 00625-2023UPG
Request Rec'd: 06/12/2023
Approval Date: 06/12/2023 DS
Permit Expires: 12/12/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Four Rivers Sanitation Authority 3501 Kishwaukee Street Rockford, IL 61109 (None) County Contact: Jim Reader 815/387-7587	FACILITY - name and address where tanks are located: Rock River Water Reclamation District 3333 Kishwaukee Street Rockford, IL 61109 Winnebago County Contact: Terry Stoll 815/387-7588
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
15	Diesel Fuel	20,000	Currently in use	Federal

Tank 15 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350j	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Alarm

Summary of Work

Replacing obsolete Auto Stic Jr with Veeder Root TLS 350J. Replacing sensors, and over fill alarm. ATG certification will be completed after installation.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Howard Lee & Sons Inc. 4093 Perryville Road PO Box 446 Cherry Valley, IL 61016	Contact Person: Vicky Buhl Phone: 815/298-3767 Email: patricko@hleeasons.com Contractor License # IL456 Exp. 3/20/2024

Sincerely,

Daniel Starks