



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	6021338
Permit #:	00488-2023UPG
Request Rec'd:	05/08/2023
Amended Date:	06/13/2023 DS
Approval Date:	05/08/2023 DS
Permit Expires:	11/08/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Andy Wall 616/233-6754	FACILITY - name and address where tanks are located: New Baden Moto 409 East Hanover New Baden, IL 62265 Clinton County Contact: Rob Whittington 618/233-6754
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
3	B-11	8,000	Currently in use	Federal
4	Gasoline - Regular	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000L	New
Piping	Aboveground	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000L	New
Piping	Aboveground	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Summary of Work

REPLACE THE EXISTING VENT LINES. RUN NEW LINES TO CANOPY COLUMNS AND STUB OUT 4' ABOVE CANOPY . FIND THE EXISTING VENT LINES AT THE TANKS AND CAP OFF. REMOVE THE EXISTING ISLAND FORMS AND SET DISPENSERS AT GRADE. REPLACE THE DIESEL SINGLEWALL SPILL BUCKET WITH A DOUBLE WALL SPILL BUCKET.

Special Contingencies

Amendment Reason:

Diesel spill bucket was damaged, snow plow ring. We will be replacing the spill bucket.

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Terry Smith
Phone: 314/267-1231
Email: terrys@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2024

Sincerely,



Daniel Starks