



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2000995
Permit #: 00641-2023CAT
Request Rec'd: 06/14/2023
Approval Date: 06/14/2023 DS
Permit Expires: 12/14/2023

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ozinga Bros., Inc, 19001 Old LaGrange Road Mokena, IL 60448 Cook County Contact: Michael Saldarelli 312/656-8393	FACILITY - name and address where tanks are located: Ozinga Bros., Inc. 200 West Jarvis Avenue Des Plaines, IL 600181952 Cook County Contact: Richard Slager 312/656-8393
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Dyed Diesel	10,000	Currently in use	Federal
12	Diesel Fuel	20,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Removing

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Removing

NACE certified designer

NACE certified designer number

Method of integrity assessment of tanks

Summary of Work

REMOVING SACRIFICIAL ANODES DUE TO THE PROGRAMMING OF POSITIVE SHUT DOWN ON NON-DESCRIMINATING SUMP SENSORS ON BOTH TANKS.

Special Contingencies

Completing work to satisfy N.O.V.s

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Superior Petroleum Marketers, Inc. 2336 Albright Lane P. O.Box 4648 Wheaton, IL 601894648	Contact Person: Steve Tuttle Phone: 630/588-1198 Email: tuttle.steve11@gmail.com Contractor License # IL2087 Exp. 2/4/2024

Sincerely,

Daniel G. Starks

Daniel Starks