



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2016452  
Permit #: 00653-2023UPG  
Request Rec'd: 06/15/2023  
Approval Date: 06/15/2023  
Permit Expires: 12/15/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Norman Junejo 7700 S. Kedzie Chicago, IL 60652 Cook County Contact: NomanJunejo 312/731-4896	<b>FACILITY</b> - name and address where tanks are located: 7700 Kedzie Gas Corp. 7700 S. Kedzie Chicago, IL 60652 Cook County Contact: 312/731-4896
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	8,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Shear Valves	New
Piping	Other Steel Riser	New

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Piping	Shear Valves	New
Spill Containment Device	Double Wall Spill Bucket	New

**Summary of Work**

Both spill containers and fill riser pipes will be replaced with double walled containers. The shear valves in dispenser #7/8 will be raised to the proper height.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Seán Keane

Raul Valdivia