



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2023475
Permit #: 00654-2023UPG
Request Rec'd: 06/15/2023
Approval Date: 06/16/2023 SB
Permit Expires: 12/18/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Kedzie Citgo, Inc. 908 Pfingston Rd. Glenview, IL 60025 Cook County Contact: Niminon Abraham 847/338-3333	FACILITY - name and address where tanks are located: Kedzie Citgo, Inc. 11501 S. Kedzie Ave. Merrionette Park, IL 60803 Cook County Contact: Joy Jacob 847/338-3333
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal
8	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Dig down to the tank top is needed to Change the Risers for Regular and Diesel spill buckets. Drop tubes need to be replaced for Regular and Diesel

All the 3 STP containments will be added with retrofit kits and new manholes. No digdown to Tanktop is needed for this

Thank you

Innovative Team

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Innovative Constructions Technology LLC 3112 Aviara Court Naperville, IL 60564	Contact Person: RAMACHANDRA RAJ penumatsa Phone: 630/747-3404 Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2024

Sincerely,

A handwritten signature in dark ink, reading "Shelly Bradley". The script is cursive and fluid, with the first name "Shelly" and last name "Bradley" written in a single continuous stroke.

Shelly Bradley