

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2010507
Permit #: 00655-2023CAT
Request Rec'd: 06/15/2023
Approval Date:06/16/2023 SB
Permit Expires: 12/18/2023

# <u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

M & B Energy, Inc. 397 Hogan St. Bolingbrook, IL 60490

Cook County

COOK County

Contact: Harry Singh 630/709-4375

**FACILITY** 

- name and address where tanks are located:

M & B Energy, Inc. 795 West Golf Road Des Plaines, IL 60016 Cook County

Contact: Harry Singh 630/709-4375

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	10,000	Currently in use	Federal

#### **Tank 2 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

#### NACE certified designer NACE certified designer number Method of integrity assessment of tanks

#### **Summary of Work**

Install (1) 9lb anode in the premium STP sump on the piping.

### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: LeeH@protanicinc.com Contractor License # IL1413 Exp. 9/26/2024			

Sincerely,

Shelly Bradley

Shelly Bradley