



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021812
Permit #: 00659-2023UPG
Request Rec'd: 06/19/2023
Approval Date: 06/20/2023
Permit Expires: 12/20/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Charles Lange 5514 S. King Drive Chicago, IL 60637 Cook County Contact: Chris Lange 773/224-8420	FACILITY - name and address where tanks are located: Falcon Fuel #1 8301 S. Cottage Grove Chicago, IL 60619 Cook County Contact: Ahmad Sokkary 708/870-1660
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	8,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Other Submersible Pump	New
Piping	Flex Connector Steel	New
Piping	Ball Valves	New
Piping	Single Wall STP/Tanktop Sump	New

Summary of Work

Removing existing submersible, ball valve, and leak detector on Premium tank. Installing new singlewall containment sump, ball valve, mechanical leak detector, flex connector and FE Petro submersible.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Raul Valdivia

For Office Use Only

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing