



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3026407
Permit #: 00672-2023ABN
Request Rec'd: 06/20/2023
Approval Date: 06/20/2023 DS
Permit Expires: 12/20/2023

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon-in-place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Paige and Dylan, LLC 2080 N. Henderson Street Galesburg, IL 61401 Knox County Contact: Jeffery Klinck 309/342-4121	FACILITY - name and address where tanks are located: Paige and Dylan, LLC 2080 N. Henderson Street Galesburg, IL 61401 Knox County Contact: Jeffery Klinck 309/342-4121
--	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
2	500	Used Oil	Inert material mixed with portland cement	Tank is located near building foundation

Location of tanks being abandoned

Tank is location in close proximity to the existing building

Location of piping being abandoned

No piping mentioned in permit application

Explanation of Why Waiver is Required

Partner observed inground piping on the southwest portion of the shop, near the bulk fluids storage area. The pipe appeared to be connected to an exterior wall-mounted pipe resembling a UST vent pipe. In the vicinity of the exterior wall-mounted pipe, Partner also observed two small manhole covers. On-site personnel did not know the purpose of the manhole covers or the piping and were unaware of any additional UST's currently or formerly situated at the subject property. However, after the site visit, the subject property owner had an equipment vendor open the manholes. One of these manholes contained a sump for a water removal system while the other appeared to be an approximately 500 gallon used oil UST. Chase Environmental group was hired by Partner to perform the decommissioning and site assessment results for the UST once the permit is approved by the OSFM. At this time, no samples have been collected and no IEMA number has been assigned to this UST. With the UST being located near the building foundation, the potential for loss to the support of that structure is the reason this waiver is requested for abandoning the tank in place.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Chase Environmental Group, Inc. 11450 Watterson Court Louisville, KY 40299	Contact Person: Zack Page Phone: 217/971-6120 Email: zpage@chaseenv.com Contractor License # IL2036 Exp. 3/17/2025

Sincerely,

Daniel G. Starks

Daniel Starks