

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2040586
Permit #: 00684-2023UPG
Request Rec'd: 06/22/2023
Approval Date:06/22/2023 DS
Permit Expires: 12/22/2023

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

7-Eleven, Inc.

3200 Hackberry Road - Gas Compliance

Irving, TX 75063 (None) County

Contact: Visal Patel 815/307-5432

FACILITY

- name and address where tanks are located:

7-Eleven Store #33144 2020 Sheridan Road Zion, IL 60099 Lake County

Contact: Laji Jacob 757/490-6339

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New

Summary of Work

Replace spill container with Double wall, riser and drop tube.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc. 19659 South 97th Avenue

Janiel J. Starke

Mokena, IL 60448

Contact Person: Ron Anderson

Phone: 708/243-9081

Email: steve@andersonpump.com

Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks