



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2017115  
Permit #: 00685-2023UPG  
Request Rec'd: 06/22/2023  
Approval Date: 06/22/2023 DS  
Permit Expires: 12/22/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Steve Borta 8415 Shady Lane Wonder Lake, IL 60097 McHenry County Contact: Steve Borta 815/725-0854	<b>FACILITY</b> - name and address where tanks are located: Steve Marathon 3417 Thompson Wonder Lake, IL 60097 McHenry County Contact: Steven J Borta 815/728-0854
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	10,000	Currently in use	Federal
5	Gasoline - Premium	10,000	Currently in use	Federal
6	Diesel Fuel	2,500	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

Proposing to remove and replace the diesel fill/spill and riser (EBW/Defender Grade Level, Double wall, 5 gallon spill containment), Vapor riser (Stae II Vapor Recovery valves and caps) and OPV (non-coaxial drop tubes, caps and adaptors) and 44" manways.

Proising to remove and replace to RUL & PUL fill/spill and riser (EBW/Defender Grade Level, Double wall, 5 gallon spill containment) and OPV (non-coaxial drop tubes, caps and adaptors) and 44" manways

Bust out and replace 8'X12' section on concrete tank pad for Diesel tank

Bust out and replace 8'X24' section of concrete tank pad for RUL/PUL

## Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
U.S. Venture, Inc. 425 Better Way Appleton, WI 54915	Contact Person: Danyelle Docter Phone: 920/243-5722 Email: ddocter@usoil.com Contractor License # IL002403 Exp. 4/11/2024

Sincerely,



Daniel Starks