



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2019574  
Permit #: 00691-2023UPG  
Request Rec'd: 06/23/2023  
Approval Date: 06/23/2023 SB  
Permit Expires: 12/26/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |   |
|--|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>U.S. Citgo Oil, Inc.<br>520 Newport Ct.<br>Island Lake, IL 60042<br>McHenry County<br>Contact: Eddie Wood 312/662-3935 | <b>FACILITY</b><br>- name and address where tanks are located:<br>U.S. Citgo Oil, Inc.<br>520 W. Newport Circle<br>Island Lake, IL 60042<br>Lake County<br>Contact: Eddie Wood 312/662-3935 |
|--|---|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 6      | Gasoline - Premium | 12,000   | Currently in use | Federal          |

**Tank 6 Equipment**

| Equipment Type             | Permit Equipment         | Action  |
|----------------------------|--------------------------|---|
| Spill Containment Device   | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |

**Summary of Work**

Replacing the Singlewall spill bucket with double wall. Changing the drop tube and riser for this. Digdown to the tank top is needed for changing the riser for this job

Thank you  
Innovative Team

**Special Contingencies**

|  |  |
|--|--|
| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>                                      |  |
| Innovative Constructions Technology LLC<br>3112 Aviara Court<br>Naperville, IL 60564 | Contact Person: RAMACHANDRA RAJ penumatsa<br>Phone: 630/747-3404<br>Email: iconstructions81@gmail.com<br>Contractor License # IL002453 Exp. 2/7/2024 |

Sincerely,

Shelly Bradley