



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2010054  
Permit #: 00695-2023UPG  
Request Rec'd: 06/23/2023  
Approval Date: 06/26/2023 DS  
Permit Expires: 12/27/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Jagtar Singh 750 Glenwood Dryer Road Glenwood, IL 60425 Cook County Contact: Balwinder Kaur 773/671-9502	<b>FACILITY</b> - name and address where tanks are located: Citgo 750 Glenwood Dryer Road Glenwood, IL 60425 Cook County Contact: Balwinder Kaur 773/671-9502
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	8,000	Currently in use	Federal
5	Gasoline - Premium	8,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping	New
Piping	Flex Connector Steel	New

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping	New
Piping	Flex Connector Steel	New

**Summary of Work**

Vent riser relocation. Remove vent risers, add 20' of new singlewall fiberglass pipe connected to existing, install new flex connectors, reinstall existing vent risers.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks