



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	5026294
Permit #:	00696-2023UPG
Request Rec'd:	06/26/2023
Approval Date:	06/26/2023 DS
Permit Expires:	12/27/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231</p>	<p>FACILITY - name and address where tanks are located: Casey's General Store #2587 270 South Crossing Drive Sherman, IL 62684 Sangamon County Contact: Jill Reams-Widder 515/965-6238</p>
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	12,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Overfill drop tube valve could not be removed from existing spill containment manhole for triennial inspection. Removing existing manhole and valve. Replacing with new double wall spill containment manhole and replacing overfill valve. Performing inspection.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Total Petroleum Service Company 2421 Washington Road Washington, IL 61571</p>	<p>Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2024</p>

Sincerely,

Daniel Starks