

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 3017358
Permit #: 00701-2023UPG
Request Rec'd: 06/26/2023
Approval Date:06/26/2023 DS
Permit Expires: 12/27/2023

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

#### **OWNER OF TANKS**

- Corporation, partnership, or other business entity:

Casey's Retail Company

3305 SE Delaware Ave. P.O. Box 3004

Ankeny, IA 50021

Contact: Lee Lytle 515/446-6231

#### **FACILITY**

- name and address where tanks are located:

Casey's General Store #1422 102 East Second Street Glasford, IL 61533 Peoria County

Contact: Patty Schubert 515/965-6238

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

## **Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

## **Summary of Work**

Overfill drop tube valve failed triennial inspection. Unable to remove from spill containment manhole. Replacing manhole with double wall spill containment and reinstalling drop tube valve after inspection.

# **Special Contingencies**

O. S. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2024			

Sincerely,

Daniel Starks