



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY

Facility #: 2006865
Permit #: 00395-2023UPG
Request Rec'd: 04/17/2023
Approval Date: 04/17/2023 DS
Extension Date: 06/26/2023
Permit Expires: 10/17/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 2351 Schaumburg Rd., LLC 2351 W. Schaumburg Rd. Schaumburg, IL 60194 Cook County Contact: 630/618-1208	FACILITY - name and address where tanks are located: Amoco #2253 2351 W. Schaumburg Rd. Schaumburg, IL 60194 Cook County Contact: Dan Olson 630/618-1208
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	12,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Removing

Summary of Work

Removing the PLLD on the manifolded line and installing mechanical non vented pressure relief required by OSFM inspector

Special Contingencies

Removing the PLLD on the manifolded line and installing mechanical non vented pressure relief required by OSFM inspector

Revision Reason:

Contractor added the wrong tank to the permit

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: Email: Contractor License # IL002420 Exp. 5/22/2023

Sincerely,

Daniel Starks