

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1018215
Permit #: 00709-2023UPG
Request Rec'd: 06/27/2023
Approval Date:06/27/2023 DS
Permit Expires: 12/27/2023

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

2nd Street BP, Inc. 11225 N. 2nd Street Machesney Park, IL 61115

(None) County

Contact: Cyril John 224/717-0376

**FACILITY** 

- name and address where tanks are located:

2nd Street BP 11225 N. 2nd Street Machesney Park, IL 61115 Winnebago County

Contact: Cyriac Lukose 847/791-1452

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Regular	10,000	Currently in use	Federal
9	Gasoline - Premium	10,000	Currently in use	Federal

#### **Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	Replacing - Piping - Flexible Double Wall

#### **Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	Replacing - Piping - Flexible Double Wall

### **Summary of Work**

Replacing (2) ss flex hoses in UDC 7/8 to bring shear valves to proper height. Lines to be precision tested after repair.

#### **Special Contingencies**

Vaniel J. Starks

PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc.
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Vicky Buhl
Phone: 815/298-3767
Email: patricko@hleesons.com
Contractor License # IL456 Exp. 3/20/2024

Sincerely,

Daniel Starks