



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1032955
Permit #: 00710-2023UPG
Request Rec'd: 06/27/2023
Approval Date: 06/28/2023 DS
Permit Expires: 12/28/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Elizabeth Patterson 984/389-1765	FACILITY - name and address where tanks are located: Circle K #1397 2300 DeKalb Avenue Sycamore, IL 60178 De Kalb County Contact: Jon Kiczula 630/888-1469
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Piping	Flexible Double Wall OmegaFlex DoubleTrac	Replacing - Piping - Fiberglass Double Wall A.O. Smith
Piping	Ball Valves	New

Summary of Work Files

See summary of work files attached to the permit application.

Summary of Work

REPAIR PIPE LEAK IN PREMIUM STP SUMP

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-7618 Email: heather_hinds@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

Daniel Starks