

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2021144
Permit #: 00715-2023LIN
Request Rec'd: 06/28/2023
Approval Date:06/28/2023 DS
Permit Expires: 12/28/2023

# <u>Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances</u>

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.** 

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141 (None) County

Contact: David P. Nye 440/792-4200

**FACILITY** 

- name and address where tanks are located:

True North Location #1917 2 Waukegan Rd. Deerfield, IL 60015

Lake County

Contact: Mohammed Azim Sozer 330/792-9999Ext.127

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
1	Gasoline - Regular	12,000	Currently in use	Federal	
2	Gasoline - Premium	12,000	Currently in use	Federal	
3	Gasoline - Regular	8,000	Currently in use	Federal	

### **Summary of Work**

Purge, clean and inspect the internal lining of the following tanks in accordance with NLPA-631 and State of Illinois 175 regulations:

## **Special Contingencies**

Janiel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2024			

Sincerely,

Daniel Starks