



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3031023
Permit #:	00722-2023UPG
Request Rec'd:	06/29/2023
Approval Date:	06/29/2023 DS
Permit Expires:	12/29/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 7-Eleven, Inc. 3200 Hackberry Road - Gas Compliance Irving, TX 75063 (None) County Contact: Visal Patel 815/307-5432	FACILITY - name and address where tanks are located: 7-Eleven Store #34460 4520 11th Street Rock Island, IL 61201 Rock Island County Contact: Amy Miller 847/608-1136
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	8,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Replacing spill containments because drop tubes are froze in risers and can not be removed

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Central Petroleum Equipment Company 109 Terrace Dr. Blue Grass, IA 52726	Contact Person: Roger Clark Phone: 563/381-5092 Email: rogercpec@revealed.net Contractor License # IL345 Exp. 6/14/2024

Sincerely,

Daniel Starks

