



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 6/29/2023

FOR OFFICE USE ONLY

Facility #: 2029035
Permit #: 00723-2023UPG
Request Rec'd: 06/29/2023
Approval Date: 06/29/2023 DS
Permit Expires: 07/11/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Bucky's Express #6441 1901 Richmond Road McHenry, IL 60050 McHenry County Contact: Jill Reams-Widder 515/446-6238
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	15,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	Replacing - Piping - Fiberglass Double Wall A.O. Smith

Summary of Work

Peplace flex on STP in containment sump

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks