



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2018702  
Permit #: 00727-2023LIN  
Request Rec'd: 06/30/2023  
Approval Date: 06/30/2023  
Permit Expires: 01/01/2024

**Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances**

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.**

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: AT&T Corp. d/b/a Illinois Bell 308 S. Akard, Room 1700 Dallas, TX 75202 (None) County Contact: Vyrl Naumann 800/566-9347	<b>FACILITY</b> - name and address where tanks are located: AT&T Chicago Q12480 10 South Canal Chicago, IL 60606 Cook County Contact: Steve Sparks 312/496-0990
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
1	Diesel Fuel	50,000	Currently in use	Federal	Existing
2	Diesel Fuel	50,000	Currently in use	Federal	Existing
3	Diesel Fuel	50,000	Currently in use	Federal	Existing
4	Diesel Fuel	50,000	Currently in use	Federal	Existing

**Summary of Work**

Purge, enter and inspect the internal lining of the following tanks in accordance with NLPA-631 and State of Illinois 175 regulations.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2024

Sincerely,

Raul Valdivia