



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3011822
Permit #: 00745-2023UPG
Request Rec'd: 07/06/2023
Approval Date: 07/06/2023 DS
Permit Expires: 01/08/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Caterpillar Tractor Co 901 W. Washington Street East Peoria, IL 616306400 Tazewell County Contact: Richard Hoffert 309/675-3986	FACILITY - name and address where tanks are located: Caterpillar Tractor Co 600 W. Washington Street East Peoria, IL 616306400 Tazewell County Contact: Joe Lee 309/675-3986
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	12,000	Currently in use	Federal
4	Gasoline - Regular	12,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing

Summary of Work

We will be digging around tank sump for tank 3 & 4 to reveal entire sump, cut sump at appropriate area and re-fiberglass in a fiberglass single wall sump extension to make the sump higher and raise the manway as well to prevent water intrusion into the sump

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/202-0792 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2024

Sincerely,

Daniel G. Starks

Daniel Starks