

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2007095
Permit #: 00748-2023UPG
Request Rec'd: 07/06/2023
Approval Date:07/06/2023 DS
Permit Expires: 01/08/2024

# Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County

Contact: Zachary Davis 937/203-7827

**FACILITY** 

- name and address where tanks are located:

Speedway #5381 314 South State Street Lockport, IL 60441 Will County

Contact: Lisa Heinzel 815/838-3563

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
17	E-85	4,000	Currently in use	Federal

## **Tank 17 Equipment**

Equipment Type	Permit Equipment	Action	
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket	

## **Summary of Work**

The drop tube is siezed so replaceing both spill bucket and drop on the E85 tank

#### **Special Contingencies**

PERSON,	FIRM	OR	COMPANY	<b>PERFORMING</b>	WORK:
		•		0	

niel J. Starke

America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9

Aurora, IL 60504

Contact Person: Ravindra Penmatsa

Phone: 312/286-6722 Email: ravi@ampsco.net

Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks