



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 2007045
Permit #: 00563-2023UPG
Request Rec'd: 05/24/2023
Amended Date: 07/07/2023 Chi
Approval Date: 05/24/2023
Permit Expires: 11/26/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Rockbuild Enterprises, Inc. 3720 Albert Lane Long Grove, IL 60047 Lake County Contact: Mohammad Khan 312/685-7363	FACILITY - name and address where tanks are located: Mobil Carwash 11501 South Halsted Street Chicago, IL 60628 Cook County Contact: Mehboob Lalani 773/264-2423
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	4,000	Currently in use	Federal
5	Gasoline - Premium	8,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Galvanized Steel Single Wall Piping	New
Piping	Shear Valves	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Galvanized Steel Single Wall Piping	New
Piping	Shear Valves	New
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Other Steel Riser	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Piping	Shear Valves	New

Summary of Work

All shear valves will be raised to the proper height in each dispenser sump.

The Premium tank spill container will be replaced with a double walled container and the riser pipe will also be replaced.

Special Contingencies

Amendment Reason:

All spill container replacment work shoudl be for tank #5 not tank #6

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Raul Valdivia