



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6006767
Permit #: 00756-2023CAT
Request Rec'd: 07/07/2023
Approval Date: 07/09/2023 DS
Permit Expires: 01/09/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Trentman Holding Company 7151 Hwy. 15 St. Libory, IL 62282 St. Clair County Contact: Casey Tillman 618/444-2526	FACILITY - name and address where tanks are located: Roger's Service & Towing LLC 7151 Hwy 15 St. Libory, IL 62282 St. Clair County Contact: Casey Trentman 618/444-2526
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	10,000	Currently in use	Federal
7	Gasoline - Premium	10,000	Currently in use	Federal
8	Diesel Fuel	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	West - Sacrificial Anode Flex Connector	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Southwest - Sacrificial Anode Flex Connector	New

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Southwest - Sacrificial Anode Flex Connector	New

NACE certified designer

NACE certified designer number

Method of integrity assessment of tanks

Summary of Work

PIPING CORROSION PROTECTION SECTION F. INSTALL CORROSION PROTECTION AT THE STPS TO PROTECT EXPOSED FLEX CONNECTORS AND OTHER METAL PORTIONS OF PRODUCT PIPING TANKS 7 & 8. SACRIFICIAL SYSTEM FAILED TEST TANKS 6 & 7. BROKEN CATHODIC PROTECTION WIRING UNDER DISPENSER 1 & 2 NEED REPAIRED AND RETESTED. SAYS WATER COVERS BOOTS NEEDS ANODES

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Tanknology
880 Church Road
Elgin, IL 60123

Contact Person: Linda Przydzial
Phone: 210/887-0309
Email: dhollander@tanknology.com
Contractor License # IL2089 Exp. 2/23/2024

Sincerely,



Daniel Starks