



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Revised**

**FOR OFFICE USE ONLY**

Facility #: 3011822  
Permit #: 00745-2023UPG  
Request Rec'd: 07/06/2023  
Approval Date: 07/06/2023 DS  
Extension Date: 07/10/2023  
Permit Expires: 01/08/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Caterpillar Tractor Co 901 W. Washington Street East Peoria, IL 616306400 Tazewell County Contact: Richard Hoffert 309/675-3986	<b>FACILITY</b> - name and address where tanks are located: Caterpillar Tractor Co 600 W. Washington Street East Peoria, IL 616306400 Tazewell County Contact: Joe Lee 309/675-3986
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	12,000	Currently in use	Federal
4	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor	Reusing Existing

**Summary of Work**

We will vac out rock around the tank sump down a few inches below nearest flat area below domed top but above all product/electrical entries. We will cut sump at appropriate area and re-fiberglass in a fiberglass single wall sump extension to make the sump higher and raise the manway as well to prevent water intrusion into the sump  
No piping will be broken or replaced

## Special Contingencies

### **Amendment Reason:**

Picked wrong item. We are not breaking any piping and need to fix Permit Piping will not be broken. I had made sure the option did show piping will not be broken and it is still showing all the inspections that will not be needed. Let me know if there is something else that needs fixed to show no piping to be broken. Thanks.

### **Amendment Reason:**


Picked wrong item. We are not breaking any piping and need to fix Permit Piping will not be broken. I had made sure the option did show piping will not be broken and it is still showing all the inspections that will not be needed. Let me know if there is something else that needs fixed to show no piping to be broken. Thanks.

### **Revision Reason:**

Sump will be heightened without any piping being broken

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/202-0792 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2024

Sincerely,



Daniel Starks