



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1015662
Permit #: 00781-2023ABN
Request Rec'd: 07/14/2023
Approval Date: 07/16/2023 DS
Permit Expires: 01/16/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Arthur J. Johnson Family Limited Partnership 1305 12th Avenue Rock Falls, IL 61071 (None) County Contact: Kathy Peugh 815/625-6380	FACILITY - name and address where tanks are located: Express Lane Shell 1801 Locust Street Sterling, IL 61081 Whiteside County Contact: Simon Olalde 815/625-6380
--	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
4	10,000	Gasoline - Regular	Inert material mixed with portland cement	
6	4,000	Gasoline - Premium	Inert material mixed with portland cement	

Explanation of Why Waiver is Required

T4 regular tank is located in area surround by overhead wires and right next to the canopy - building - price sign.

Equipment necessary to pull the tank would not be able to access the area.

T6 premium tank is located directly next to T5 premium which is still going to be used.

CONTAMINATED SITE!

IEMA Number

2023-0557

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2024

Sincerely,

Daniel Starks