



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2009127  
Permit #: 00784-2023ABN  
Request Rec'd: 07/09/2023  
Approval Date: 07/17/2023 DS  
Permit Expires: 01/17/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Bucky's Express #6520 1000 N. York Road Elmhurst, IL 60126 Du Page County Contact: Nicole Tunstill 402/558-9860
--	---

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
2	12,000	Gasoline - Premium	Inert material mixed with portland cement	

**Explanation of Waiver for Abandonment**

Tank is in an existing tank field. Removal would put the other tanks in position of failure.

**CONTAMINATED SITE!**

**IEMA Number**

2023-0520

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: <a href="mailto:natem@rstenstrom.com">natem@rstenstrom.com</a> Contractor License # IL1890 Exp. 3/7/2024

Sincerely,

Daniel Starks