



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	6010001
Permit #:	00785-2023UPG
Request Rec'd:	07/13/2023
Approval Date:	07/17/2023 DS
Permit Expires:	01/17/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sufian & Noor, Inc. 2501 College Avenue Alton, IL 62002 Madison County Contact: 618/465-4394	FACILITY - name and address where tanks are located: Jim's Corner 2501 East College Avenue Alton, IL 62002 Madison County Contact: Sufian Shinhadeh 618/465-4394
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Out of service	Federal
6	Gasoline - Premium	8,000	Out of service	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve
Piping	Other Steel Riser	Replacing - Piping - Fiberglass Double Wall

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	Replacing - Piping - Fiberglass Double Wall
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Installing new DW spill buckes, replacing all 4" riser pipes, installing new overfill drop tubes.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 4444 Union Blvd. St. Louis, MO 63115	Contact Person: Terry Smith Phone: 314/267-1231 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2024

Sincerely,

Daniel G. Starks

Daniel Starks