



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2000428  
Permit #: 00741-2023UPG  
Request Rec'd: 07/06/2023  
Amended Date: 07/17/2023 DS  
Approval Date: 07/06/2023 DS  
Permit Expires: 01/08/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mohsen, Inc. 3213 Mission Avenue Oceanside, CA 92058 (None) County Contact: Nader Arabshahi 760/754-2009	<b>FACILITY</b> - name and address where tanks are located: Mohsen Oil, Inc. 24001 W. Lorenzo Road Wilmington, IL 60481 Will County Contact: Nader Arashahi 760/654-2009
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Kerosene	4,000	Out of service	Federal
12	Racing Fuel	4,000	Out of service	Federal

**Tank 11 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Other Steel Riser	New

**Tank 12 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Other Steel Riser	New

**Summary of Work**

Replacing failed single wall spill containers with double walled spill containers for the Kerosene and Racing fuel tanks. Fill riser pipes also required replacement with soil isolation wrapped galvanized steel riser pipes for both tanks.

**Special Contingencies**

**Amendment Reason:**

Fill riser pipes also required replacement during the spill container work.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks