

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2002267
Permit #: 00797-2023UPG
Request Rec'd: 07/18/2023
Approval Date:07/18/2023 DS
Permit Expires: 01/18/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Speedway, LLC P.O. Box 1500 Springfield, OH 45501

Clark County

Contact: Zachary Davis 937/203-7827

FACILITY

- name and address where tanks are located:

Speedway #7422 7859 S. Harlem Avenue Burbank, IL 60459 Cook County

Contact: Rob Vondras 708/430-2227

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Gasoline - Regular	20,000	Currently in use	Federal
12	Gasoline - Regular	20,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

The adapters are seized so replacing spills and drop tubes on both RUL tanks as the drop tube failed compliance testing

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

aniel y. Starke

America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9

Aurora, IL 60504

Contact Person: Ravindra Penmatsa

Phone: 312/286-6722 Email: ravi@ampsco.net

Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks