



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 1015662  
Permit #: 00799-2023UPG  
Request Rec'd: 07/17/2023  
Approval Date: 07/18/2023 DS  
Permit Expires: 01/18/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Arthur J. Johnson Family Limited Partnership 1305 12th Avenue Rock Falls, IL 61071 (None) County Contact: Kathy Peugh 815/625-6380	<b>FACILITY</b> - name and address where tanks are located: Express Lane Shell 1801 Locust Street Sterling, IL 61081 Whiteside County Contact: Simon Olalde 815/625-6380
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Premium	4,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Polyethylene Chase	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping

**Summary of Work**

Remove frp piping, all tank top equipment. Installing new DW spill bucket, STP containment sump, new flex pipe, adding dispenser sumps

**Special Contingencies**

Replaced piping exceeds 20 feet or 50% of the total pipe run.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks