



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Extended**

**FOR OFFICE USE ONLY**

Facility #: 2010057  
Permit #: 00111-2023UPG  
Request Rec'd: 01/31/2023  
Approval Date: 01/31/2023 DS  
Extension Date: 07/20/2023  
Permit Expires: 02/01/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Crete 2, LLC 23802 Volbrecht Road Crete, IL 60417 (None) County Contact: Alex Singh 219/775-0313	<b>FACILITY</b> - name and address where tanks are located: Crete 2, LLC 1351 Main Street Crete, IL 60417 Will County Contact: Nasir Yaqoob 219/775-0313
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline	12,000	Out of service	Federal
6	Gasoline	12,000	Out of service	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New
Spill Containment Device	Single Wall Spill Bucket	New
Overfill Prevention Device	Overfill Alarm	New
Piping	Flexible Double Wall A.P.T. Poly Tech S150SC	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
Piping	Ball Valves	New
Piping	Shear Valves	New

## Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New
Spill Containment Device	Single Wall Spill Bucket	New
Overfill Prevention Device	Overfill Alarm	New
Piping	Flexible Double Wall A.P.T. Poly Tech S150SC	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
Piping	Ball Valves	New
Piping	Shear Valves	New

### Summary of Work

Upgrading tanks 5&6 with new containment, double-wall piping, new leak detection system as part of a full site rebuild.

### Special Contingencies


Replaced piping exceeds 20 feet or 50% of the total pipe run. Upgrading tanks 5&6 with new containment, double-wall piping, new leak detection system as part of a full site rebuild. Installing single wall dispenser sumps under each dispenser.

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone:  
Email:  
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks