



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended/Revised

FOR OFFICE USE ONLY

Facility #: 2045212
Permit #: 00964-2022INS
Request Rec'd: 09/01/2022
Approval Date: 09/07/2022 DS
Extension Date: 07/25/2023
Permit Expires: 09/08/2023

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: M3 North America, LLC 2111 Pratt Blvd. Elk Grove Village, IL 60007 Cook County Contact: Sevastian Madej 224/265-0453	FACILITY - name and address where tanks are located: KLC Global Services 2045 E Pratt Blvd Elk Grove Village, IL 60007 Cook County Contact: Marcin Kotwica 224/265-0453
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	30,000	Installed/Not in Use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Single Wall Spill Bucket	New
Corrosion Protection - Tank	Composite Non-Corrosive	New
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Tank	Composite Double Wall Zorn Elutron	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Leak Detection - Piping	Discriminating Sump Sensor with positive shutdown	New
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions. There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Special Contingencies

Amendment Reason: piping layout has changed, we will be moving the vent north of the tank to the fence, we have changed the product line run from the west end of the tank now instead of the east end , we are also changing the AATG to a Veeder Root TLS 450 plus with electronic line leak detection

Amendment Reason:


piping layout has changed, we will be moving the vent north of the tank to the fence, we have changed the product line run from the west end of the tank now instead of the east end , we are also changing the AATG to a Veeder Root TLS 450 plus with electronic line leak detection

Revision Reason:

Removed sensor with monitor. NOTE: All sump sensors are non-discriminating

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Petroleum Technologies Equipment, Inc. 8447 West 44th Place Lyons, IL 60534	Contact Person: Thomas Doherty Phone: Email: Contractor License # IL2051 Exp. 1/17/2024

Sincerely,



Daniel Starks