

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended

## FOR OFFICE USE ONLY

Facility #: 6038126
Permit #: 00814-2023UPG
Request Rec'd: 07/21/2023
Amended Date:07/25/2023 DS
Approval Date: 07/24/2023 DS
Permit Expires: 01/24/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

#### OWNER OF TANKS

- Corporation, partnership, or other business entity:

Casey's Retail Company

3305 SE Delaware Ave. P.O. Box 3004

Ankeny, IA 50021

Contact: Jaimon Lukose 515/446-6231

#### **FACILITY**

- name and address where tanks are located:

Casey's General Store 504 Hartmann Lane O Fallon, IL 62269 St. Clair County

Contact: Melinda Hickam 515/965-6238

### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal

# Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Fiberglass Riser	New

# **Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Other Fiberglass Riser	New

# **Summary of Work**

Replacing both prob risers on both tanks. using fibglass risers

# **Special Contingencies**

# **Amendment Reason:**

using fiberglass on risers.

### PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service

4444 Union Blvd. St. Louis, MO 63115 Contact Person: Terry Smith Phone: 314/797-0468

Email: cbayne@unitedpetro.com

Contractor License # IL002402 Exp. 2/10/2024

Sincerely, Daniel J. Starks

Daniel Starks