



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2023196
Permit #: 00835-2023UPG
Request Rec'd: 07/27/2023
Approval Date: 07/27/2023 DS
Permit Expires: 01/29/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: North Villa Mart, LLC 350 E. North Avenue Villa Park, IL 60188 Du Page County Contact: Armar Patel 847/863-2448	FACILITY - name and address where tanks are located: Amoco 15721 350 E. North Avenue Villa Park, IL 60188 Du Page County Contact: Amar Patel 847/863-2448
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Diesel Fuel	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall	Replacing - Piping - Fiberglass Double Wall

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall	Replacing - Piping - Fiberglass Double Wall

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall	Replacing - Piping - Fiberglass Double Wall

Summary of Work

Rerouting pipe runs to allow for building expansion by others. Removing approx. 30' of double wall fiberglass pipe (4" over 3") for (3) products. Installing new double wall fiberglass pipe (4" over 3") connected to existing pipe.

Special Contingencies

Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTE: No sumps will be affected and sensors are existing

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks