



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2007020  
Permit #: 00841-2023UPG  
Request Rec'd: 07/28/2023  
Approval Date: 07/31/2023  
Permit Expires: 01/31/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Northern Associates, Inc. 2545 W. Peterson Ave., Suite 101 Chicago, IL 60659 Cook County Contact: Nusrat H. Choudhri 773/835-7786	<b>FACILITY</b> - name and address where tanks are located: BP Gas Station 150 W. 63rd Street Chicago, IL 60621 Cook County Contact: Muzafar Ali 773/483-1200
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Diesel Fuel	10,000	Currently in use	Federal

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Shear Valves	Replacing - Piping - Fiberglass Double Wall
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Ball Valves	New
Piping	Flex Connector Steel	New

**Summary of Work**

Tank #8 will be converted to E85 product which will require the changing of the tank probe, sump sensor, mechanical line leak detector, overfill prevention drop tube, shear valve, ball valve, flex connector and STP.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Seán Keane

Raul Valdivia