



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 2042930
Permit #: 00796-2023UPG
Request Rec'd: 07/18/2023
Amended Date: 07/31/2023 DS
Approval Date: 07/18/2023 DS
Permit Expires: 01/18/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sibley Petroleum, LLC 667 East Sibley Blvd. Dolton, IL 60419 Cook County Contact: Amin Ijbara 708/336-0122	FACILITY - name and address where tanks are located: Sibley Petroleum, LLC 667 East Sibley Blvd. Dolton, IL 60419 Cook County Contact: Amin Ijbara 708/336-0122
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	4,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New
Piping	Flex Connector Steel	New
Piping	Ball Valves	New
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Non-Discriminating Sump Sensor

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Summary of Work

The Diesel UST system will be converted to E85 product. The items to be changed are the probe, STP including flex connector and ball valve, STP sump sensor, and overfill prevention drop tube.


Special Contingencies

Amendment Reason:


The list of items to be replaced was not complete.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks

For Office Use Only		
Dispenser 1/2 Equipment		
Equipment Type	Permit Equipment	Action
 Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing