



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2026579  
Permit #: 00844-2023UPG  
Request Rec'd: 07/31/2023  
Approval Date: 07/31/2023 DS  
Permit Expires: 01/31/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Jericho LLC 207 W Kendall Dr Yorkville, IL 60560 Kendall County Contact: Ratos James G 630/553-7381	<b>FACILITY</b> - name and address where tanks are located: Sugar Grove Merit Gas 9 S. 595 Rt. 47 Sugar Grove, IL 60554 Kane County Contact: Ray Awad 630/466-4557
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	10,000	Currently in use	Federal
8	Gasoline - Premium	10,000	Currently in use	Federal

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

The site has co-axial poppeted drop tubes but those drop tube are discontinued by opw and difficult but the site has overfill alarm which is working so changing the overfill protection to overfill alarm for RUL and PUL

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel Starks