

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2021075
Permit #: 00850-2023UPG
Request Rec'd: 08/03/2023
Approval Date:08/04/2023 SB
Permit Expires: 02/06/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Roosevelt Properties, LLC 8060 Lawndale Ave. Skokie, IL 60076 Cook County

Contact: Mohammad Yaqoob 847/679-5398

**FACILITY** 

- name and address where tanks are located:

Ridge Shell Mart, Inc. 399 Ridge Rd. Wilmette, IL 60091 Cook County

Contact: Andrei Orban 847/679-5398

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	8,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal

#### Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing

#### Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing

### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing

#### **Summary of Work**

All ball float assemblies will be removed. The site will remian using the existing overfill prevention drop tubes.

#### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:			
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024		

Sincerely,

Shelly Bradley

Shelly Bradley