



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2009067
Permit #:	00682-2023CAT
Request Rec'd:	06/21/2023
Amended Date:	08/06/2023 DS
Approval Date:	06/22/2023 DS
Permit Expires:	12/22/2023

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sibi Kadalimattom 1701 W Harrison Maywood, IL 60153 Cook County Contact: Sibi or Manoj Kadalimattom 708/343-8705	FACILITY - name and address where tanks are located: Maywood Mart Care 1701 W. Harrison Maywood, IL 60153 Cook County Contact: Sibi or Manoj Kadalimattom 708/343-8705
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	8,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Amendment Reason:

Dispensers do not need CP added. Flex connectors under #1/2 and #3/4 are non-metallic. However, all 3 STP sumps have water and need sacrificial anodes installed. Discussed this issue with Chris Lehnert regarding NOV Number: E0020231401.

Summary of Work

Installing sacrificial anodes on piping in all 3 STP sumps.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
1058 National Parkway
Schaumburg, IL 601734519

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2025

Sincerely,



Daniel Starks