



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2009057
Permit #: 00861-2023UPG
Request Rec'd: 08/07/2023
Approval Date: 08/07/2023 DS
Permit Expires: 02/07/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Power Petroleum, LLC 208 E. Tall Trees Lane Palatine, IL 60067 Cook County Contact: Bhupinder Dhaliwal 224/423-7659	FACILITY - name and address where tanks are located: Mobil Hicks 2101 Hicks Road Rolling Meadows, IL 60008 Cook County Contact: Bhupinder Dhaliwal 815/423-7659
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal
7	Gasoline - Premium	12,000	Currently in use	Federal
8	Diesel Fuel	12,000	Currently in use	Federal

Dispensers on the Permit

Dispenser	Action
3/4	Sump / Sensors Changing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
Leak Detection - Piping	Non-Discriminating Sump Sensor with positive shutdown	New

Summary of Work

Installing Bravo fiberglass dispenser containment sump under dispenser 3/4. Installing new Veeder Root 794380-323 sensor

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/209-6640 Email: natem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel G. Starks

Daniel Starks

For Office Use Only

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing