

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 2023139
Permit #: 00647-2023UPG
Request Rec'd: 06/15/2023
Amended Date: 08/08/2023 DS
Approval Date: 06/15/2023 DS
Permit Expires: 12/15/2023

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:
- name and

Irfan Moten 6546 N. Sauganash Lincolnwood, IL 60712

Cook County

Contact: Irfan Moten 773/418-2300

name and address where tanks are located:
 M Sons d/b/a Wheeling Shell
 775 W. Dundee Rd.

Wheeling, IL 60090 Cook County

Contact: Irfan Moten 773/418-2300

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	6,000	Currently in use	Federal
3	Gasoline - Regular	8,000	Currently in use	Federal
4	Gasoline - Regular	10,000	Currently in use	Federal
5	Diesel Fuel	4,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Summary of Work

The store building will be remodelled and the tank monitor system will be relocated to a different part of the building.

Special Contingencies

Amendment Reason:

The store building will be remodeled and the tank monitor system will be relocated to a different part of the building. The equipment description has been revised to show only one atg.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely, Daniel J. Starks

Daniel Starks