



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	1008887
Permit #:	00870-2023CAT
Request Rec'd:	08/08/2023
Approval Date:	08/08/2023 DS
Permit Expires:	02/08/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Freeport Memorial Hospital 1045 West Stephenson Street Freeport, IL 61032 Stephenson County Contact: Kelly Murray 815/559-6102	FACILITY - name and address where tanks are located: Freeport Memorial Hospital 1045 West Stephenson Street Freeport, IL 61032 Stephenson County Contact: Kelly Murray 815/559-6102
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	20,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Repairing CP Sac Anode on Diesel line (Tank is Fiberglass) installing (2) 17# Sac Anodes hand digging and trenching due to short product line run.
 Any questions please feel free to call.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 800/352-2011 Email: frankg@protanicinc.com Contractor License # IL1413 Exp. 9/26/2024

Sincerely,

Daniel Starks