



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

|                            |               |
|----------------------------|---------------|
| <b>FOR OFFICE USE ONLY</b> |               |
| Facility #:                | 2030277       |
| Permit #:                  | 00873-2023UPG |
| Request Rec'd:             | 08/09/2023    |
| Approval Date:             | 08/09/2023 DS |
| Permit Expires:            | 02/09/2024    |

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |  |
|--|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Loeber Motors<br>4255 West Touhy Avenue<br>Lincolnwood, IL 60712<br>Cook County<br>Contact: MIKE LOEBER 847/675-1000 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Loeber Motors<br>4255 West Touhy Avenue<br>Lincolnwood, IL 60646<br>Cook County<br>Contact: John Martin 847/675-1000 |
|--|--|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2      | Gasoline - Regular | 5,000    | Currently in use | Federal          |

**Tank 2 Equipment**

| Equipment Type           | Permit Equipment         | Action  |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

**Summary of Work**

REPLACE EXISTING SINGLE WALL 5-GALLON SPILL BUCKET WITH 5-GALLON DOUBLE WALL BUCKET. REUSE EXISTING OVERFILL DROP TUBE.

**Special Contingencies**

|   |   |
|---|---|
| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>   |   |
| Superior Petroleum Marketers, Inc.<br>2336 Albright Lane P. O.Box 4648<br>Wheaton, IL 601894648 | Contact Person: Steve Tuttle<br>Phone: 630/588-1198<br>Email: tuttle.steve11@gmail.com<br>Contractor License # IL2087 Exp. 2/4/2024 |

Sincerely,

Daniel Starks