



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 8/9/2023

FOR OFFICE USE ONLY

Facility #: 6016541
Permit #: 00876-2023UPG
Request Rec'd: 08/09/2023
Approval Date: 08/09/2023 DS
Permit Expires: 08/22/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: GPM Midwest, LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227 (None) County Contact: Chad Fluck 317/914-9446 | FACILITY - name and address where tanks are located: Fas Mart #5154 101 Piasa Lane Hartford, IL 62048 Madison County Contact: Rolfe Lann 804/730-1568 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 12 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 12 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|-------------------------------|--|
| Piping | Fiberglass Double Wall Ameron | Replacing - Piping - Fiberglass Double Wall Ameron |

Summary of Work

remove line at the UDC of 9/10, replace o ring, reinstall line, performed precision line test.

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Superior Acquisition LLC d/b/a Superior Equipment Company 7525-A Sussex St. Louis, MO 63143 | Contact Person: Matt Gross Phone: 618/971-7126 Email: nwacker@secofuel.com Contractor License # IL002394 Exp. 3/8/2025 |

Sincerely,

Daniel Starks