



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3026408
Permit #: 00880-2023UPG
Request Rec'd: 08/10/2023
Approval Date: 08/10/2023 DS
Permit Expires: 02/12/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Knoxville Quick Stop, Inc. 319 E. Main Street Knoxville, IL 61448 Knox County Contact: Ravi Patel 646/691-0060	FACILITY - name and address where tanks are located: Knoxville Quick Stop 319 East Main Knoxville, IL 61448 Knox County Contact: Darlene Plue 309/289-6144
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	8,000	Currently in use	Federal
2	Gasoline - Premium	4,000	Currently in use	Federal
3	Gasoline - Mid-grade	4,000	Currently in use	Federal
4	Diesel Fuel	2,000	Currently in use	Federal
5	Kerosene	1,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik II

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik II

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik II

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik II

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik II

Summary of Work

Seneca Companies will Remove 5 existing Tank Probes and Existing Tank Monitor- Replace with 5 Veeder Root Probes and Veeder Root TLS 350.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Glen Davis Phone: 563/940-2896 Email: jradloff@senecaco.com Contractor License # IL598 Exp. 2/23/2024

Sincerely,



Daniel Starks