

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2020397
Permit #: 00881-2023CAT
Request Rec'd: 08/10/2023
Approval Date:08/10/2023 DS
Permit Expires: 02/12/2024

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101

(None) County
Contact: Jeremy Holland 610/625-8061

FACILITY

- name and address where tanks are located:

IL0080

1 Boulder Hill Pass Montgomery, IL 60538

Kane County

Contact: Sajimon Kora 630/896-5254

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Northeast - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Protanic, LLC

Replacing 1 9lb anode in regular STP on the flex connectors.

PERSON, FIRM OR COMPANY PERFORMING WORK:

658 North Progress Drive PO Box 80265

Daniel J. Starke

Saukville, WI 53080

Contact Person: Kylie Krombach

Phone: 262/268-1150 Email: alexp@protanicinc.com

Contractor License # IL1413 Exp. 9/26/2024

Sincerely,

Daniel Starks